STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107268
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34035

1. OWNER 7-Eleven, Inc.
MAILING ADDRESS P.O. Box 711, dallas, tx, 75221-0711

ADDRESS AT WELL LOCATION 15 North lamb Blvd SB -6B Las Vegas, NV
Subdivision Name: County: Clark

2. LOCATION SE ¼ SE ¼ Sec 31 T 20S N/S R 62 E
PERMIT/WAIVER No. 140-31-803-004
Issued by Water Resources Parcel No.

Latitude 36.15919N
Longitude 115.07982W
UTM E N
[X] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC [ ] Air [X] Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt		0	5	5
sandy silt		5	18	13
Silt with fine sand		18	23	5

Date started: 24-Sep, 20 08
Date completed: 24-Sep, 20 08

9. WELL CONSTRUCTION
Depth Drilled 23 Feet Depth Cased 22 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	22	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		sch 40	0	22

Perforations:
Type of perforation factory slotted
Size of perforation 0.02
From 7 feet to 22 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [X] Yes [ ] No 5 to 22 [ ] Pumped [X] Poured
Type: 10-20 colorado silica sand
Bentonite Chips: [X] Yes [ ] No 1 to 5 [ ] Pumped [X] Poured
Type: medium bent. Chips

7. Water Level
Static water level: 11.6 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells (Contractor)
Address 570 Corinthian Way (Contractor)
Las Vegas, NV 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012-852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2057
Signed (Driller performing actual drilling on site or contractor)
Date 9-29-08

DCNR/DWR RECEIVED SEP 29 2008 LAS VEGAS OFFICE

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY