

OFFICE USE ONLY
 Log No. 107295
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33519
 ADDRESS AT WELL LOCATION 4975 POLARIS AVE.
LAS VEGAS NEVADA

1. OWNER BUDGET SUITES AMER. LLC NV. 480 ADDRESS AT WELL LOCATION 4975 POLARIS AVE.
LAS VEGAS NEVADA
 MAILING ADDRESS 4640 S. EASTERN AVE
LAS VEGAS NEVADA
 2. LOCATION NW 1/4 NW 1/4 Sec. 29 T. 21 N/S R. 61 E. CLARK County
 PERMIT NO. 162-29-101-015 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0'	0.25	0.25
STONE WITH SAND FILL		0.25	2.5	2.25
SILTY BROWN CLAY		2.5	5.0	2.5
CALICHE		5.0	10.0	5.0
SILTY BROWN CLAY		10.0	21.0	11.0
SILTY BROWN CLAY	YES	21.0	32.0	11.0
CALICHE		32.0	35.0	3.0
MW 17				
FACILITY I.D. NO. 8-000204				
MAP DATUM WGS 84 36° 05.995 N. 115° 11.246 W.				

8. WELL CONSTRUCTION
 Depth Drilled 35 Feet Depth Cased 35 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8.5 Inches To 0 Feet 35 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>JCH 40</u>	<u>0</u>	<u>35</u>

Perforations:
 Type perforation MACHINE SLOTS
 Size perforation .020
 From 20 feet to 35 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 18 feet to 35 feet

DCNR/DWR RECEIVED
 NOV 13 2008
 LAS VEGAS OFFICE

Date started 8-5, 2008
 Date completed 8-5, 2008

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet)	Time (Hours)
DCNR/DWR RECEIVED		
AUG 11 2008		
LAS VEGAS OFFICE		

9. WATER LEVEL
 Static water level 21 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EAGLE DRILLING SERVICES LLC Contractor
 Address 7150 PLACID ST LAS VEGAS NV 89119 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 51266
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
 Signed Mindy Wikstrom 2357
 By driller performing actual drilling on site or contractor
 Date 8-6-2008