STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 107307
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34232

1 OWNER DENNIS + CAROL SINGER
MAILING ADDRESS 312 NEWHOPE DR. HENDERSON NV. 89014

ADDRESS AT WELL LOCATION 312 NEWHOPE DR. HENDERSON NV. 89014
Subdivision Name: PROMONTORY POINT County: CLARK

2 LOCATION SE ¼ NW ¼ Sec 9 T 22 N/S R 62 E
PERMIT/WAIVER No. 1780921 8037 Issued by Water Resources Parcel No.

Latitude 36° 07. 988 N
Longitude 115° 03. 346 W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3 TYPE OF WELL
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

Is this well being plugged because a replacement well was drilled?
If yes, what is replacement well NO!?

Is there an existing well log? YES
If yes, what is NDWR well log #?

4 EXISTING WELL CONSTRUCTION
Depth Drilled 19.7 Feet Depth Cased 19.7 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 40	0	19.7

Existing Perforations:
Type of perforation MACHINE SLOT
Size of perforation .020

From 9.7 feet to 19.7 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

5 WATER LEVEL
Static water level 17 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

6 Additional Notes or Comments

DCNR/DWR RECEIVED
NOV 24 2008
LAS VEGAS OFFICE

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? ☒ yes ☐ no
If well was not cleaned out to total depth, please explain why:

Was the well contaminated? ☐ yes ☒ no
Was the casing pulled? ☒ yes ☐ no
Was the casing over drilled? ☐ yes ☒ no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforater used:

From feet to feet Number of perfs per linear foot
From feet to feet Number of perfs per linear foot
From feet to feet Number of perfs per linear foot
From feet to feet Number of perfs per linear foot
From feet to feet Number of perfs per linear foot
From feet to feet Number of perfs per linear foot

8 WELL PLUGGING MATERIALS

From	feet to	Material Used	Pumped	Poured
.5	19.7	CEMENT GROUT	☒	☐
.0	.5	TOPSOIL	☐	☒
			☐	☐
			☐	☐
			☐	☐
			☐	☐

Neat Cement Fluid Weight 20 lbs/gal 1
Bentonite Grout % bentonite

Date Started 11-18-2008
Date Completed 11-18-2008

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING (Contractor)
Address 7150 PLACID ST LAS VEGAS NV 89119 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 11-18-2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

BORING LOG

Project/Client: Springless Terrace F.N.: 80092.01

Location: 312 New Hope, 16' S and 7.5' E of New Pl cor. Date: 11/16/00

Estimated Surface Elevation (ft): 1856 Total depth (ft): 21.5 Rig Type 6" hollow stem

Depth (Feet)	Sample Type	Sample Depth	Blow Count	Field Description (By: TMA)
				Surface Conditions: moist soil planted w/ grass
0				Subsurface Conditions: FORMATION: Classification, color, moisture, tightness, etc.
				0-0.3' - landscaping topsoil, silty clay, dk brn, v moist, soft w/ roots
				0.3-5.5' - Fat sandy clay, orange, v moist, soft-firm, w/ sub angl gravel to 1½" dia.
5	LB	5-10'		
	R	7.5-9'	14,22,24/4"	7.5-9.0' - weathered volcanic clayey gravel, orange, sub moist, med dense - dense, occ. sub angl gravel to 1" dia. (basalt), w/ sparkled calcite
10				9.0-12' - seepage
	R	12.5-14'	8,5,5	no recovery
15	R	15-16.5'	4,3,3	12.5-14' - med-crs sand, red brn/olive gray, v moist-sat, loose-med dense, occ layer of silty clay, orange, sat, soft
20	R	20-21.5'	7,11,27	15-16.5' - med crs sand, red brn/olv gray, v moist-sat, loose-med dense, occ silty clay layer 1-5mm thick, olive, sat, soft
				20-21.5' - fine-crs sand, dk gray/blk, sat, loose, occ sub rnd gravel to 2" dia. (basalt)
				piezometer set to 20', lower 10' screened, sand from 20-5', bentonite from 5-1, sand from 1-0'

DCNR/DWR RECEIVED NOV 24 2008 LAS VEGAS OFFICE

Note:

AMERICAN GEOTECHNICA BORING LOG.: AG SB-17