STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107354
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33716

1. OWNER Tronx L.L.C
MAILING ADDRESS P.O.Box 268859, Oklahoma City, OK 73126
MW-127

ADDRESS AT WELL LOCATION 8000 W.Lake Mead Pkwy.
Unincorporated Co.of Clark
Subdivision Name: County: Clark

2. LOCATION NW ¼ sw ¼ Sec 12 T 22S N/S R 62 E
PERMIT/WAIVER No. 178-12-301-003
Issued by Water Resources Parcel No.

Latitude 36.04753621
Longitude 115.0079914
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SW-Well Grined Sand Ybr		0	23	23
ML-Silt w/Sand Yellowish		23	28	5
MH-Elastic Silt Yellowish Br	36.5	28	42	14
MH-Elastic Silt Olive Gr		42	50	8

DCNR/DWR
RECEIVED
NOV 12 2008
LAS VEGAS OFFICE

Date started: 29-Jun , 20 08
Date completed: 29-Jun , 20 08

7. Water Level
Static water level: 38.7 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: C °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☒ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
.5	1.2	4

9. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	0	Feet	50.3	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	schd 40	schd 40	+3'	35

Perforations:
Type of perforation Sloted
Size of perforation 0.01
From 35 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 30 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 33 to 50.3 ☐ Pumped ☒ Poured
Type: CMEX 2/12
Bentonite Chips: ☒ Yes ☐ No 30 to 33 ☐ Pumped ☒ Poured
Type: WYO-BEN MEDIUM

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Mario Romero / Boart Longyear
Contractor
Address 12464 McCann Dr, Santa Fe Springs,CA 90670
Contractor
Nevada contractor's license number 21976
issued by the *State Contractor's Board* M-2313
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* Mario Romero
Signed
By driller performing actual drilling on site or contractor
Date 11-11-08

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY