

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32778

1. OWNER Kelly Jensen ADDRESS AT WELL LOCATION 1 mile west of mile marker # 37 US 93 south of Las Vegas  
 MAILING ADDRESS PO Box 444 Alamo NV 89001  
 2. LOCATION NW 1/4 NE 1/4 Sec. 17 T. 7 N. R. 61 E. Lincoln County  
 PERMIT NO. 74653 Issued by Water Resources Parcel No. 608-360-22 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE P88  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand-Boulders		0	70	70
Hard Rock		70	110	40
Fractured Rock	X	110	130	20

WGS 84  
 N 37° 20.641'  
 W 115° 09.630'  
 37.344052° N  
 115.159651° W N40 22 (TW)  
 Total Lost circulation at 130'  
 pumped in 800 gals of high  
 viscosity mud, still no return  
 so I ran casing made customer  
 an excellent well

8. WELL CONSTRUCTION  
 Depth Drilled 130 Feet Depth Cased 130 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 130 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 1/2	PVC	Sch 40	0	130

Perforations:  
 Type perforation sqw cut  
 Size perforation 1/8" x 4"  
 From 100' feet to 130 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 130 feet

DCNR/DWR  
 RECEIVED

DEC 08 2008

Date started 11-17-08  
 Date completed 11-20-08 LAS VEGAS OFFICE

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
75	21	2

2009 JAN 23 11:10 AM  
 2009 JAN 23 11:10 AM

9. WATER LEVEL  
 Static water level 65 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature cold °F Quality fair

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Davis Drilling and Pumps Contractor  
 Address HC 61 Box 54 Hiko NV 89017 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0028966  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191  
 Signed Mike Davis  
 By driller performing actual drilling on site or contractor  
 Date 11-20-08