

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY  
 Log No. **107424**  
 Permit No. \_\_\_\_\_  
 Basin **212**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **34309**

1 OWNER Schopen James E Trust ADDRESS AT WELL LOCATION 4075 AITO AVE  
 MAILING ADDRESS 4075 AITO AVE Las Vegas, NV 89115  
Las Vegas, NV 89115 Subdivision Name: \_\_\_\_\_ County: Clark

2 LOCATION NW 1/4 SE 1/4 Sec 18 T 20 N 62 E Latitude 36 12 35 48" N UTM E \_\_\_\_\_  NAD 27  
 PERMIT/WAIVER No. R-1438 140-18-710-031 Longitude 115-050-095 W N \_\_\_\_\_  NAD 83/WGS 84  
Issued by Water Resources Parcel No.

3 TYPE OF WELL  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 Is this well being plugged because a replacement well was drilled? no  
 If yes, what is replacement well NOI? \_\_\_\_\_  
 Is there an existing well log? yes  
 If yes, what is NDWR well log #? 54502

4 EXISTING WELL CONSTRUCTION  
 Depth Drilled 1 Feet 105 Depth Cased 165 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.625</u>	<u>28.55</u>	<u>.322</u>	<u>1</u>	<u>165</u>

7 WELL PLUGGING PROCEDURE  
 Was well cleaned out to total depth?  yes  no  
 If well was not cleaned out to total depth, please explain why: \_\_\_\_\_  
 Was the well contaminated?  yes  no  
 Was the casing pulled?  yes  no  
 Was the casing over drilled?  yes  no  
 If casing was left in place, please show where additional perforations were made:  
 Additional Perforations:  
 Type of perforator used: Waiver

Existing Perforations:

From	Type of perforation	Size of perforation	feet to	feet

Additional Perforations:

From	Type of perforator used:	feet to	feet	Number of perfs per linear foot

5 WATER LEVEL  
 Static water level 30 feet below land surface  
 Artesian flow na G.P.M. n/a P.S.I.  
 Water temperature n/a °F Quality n/a

8 WELL PLUGGING MATERIALS

From	Material Used	feet to	feet	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<u>160</u>	<u>neat cement</u>	<u>0</u>	<u>feet</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments  
pump 2.5 yards of neat cement

**DCNR/DWR RECEIVED**

DEC 30 2008

**LAS VEGAS OFFICE**

Neat Cement Fluid Weight 94 lbs/gal 5.2  
 Bentonite Grout \_\_\_\_\_ % bentonite  
 Date Started 12-30-08  
 Date Completed 12-30-08

9 DRILLER'S CERTIFICATION  
 This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.  
 Name WDC Exploration & Wells Contractor  
 Address 570 Corinthian way Contractor  
N. Las Vegas 89030  
 Nevada contractor's license number \_\_\_\_\_  
 issued by the State Contractor's Board 0012852  
 Nevada driller's license number issued by the  
 Division of Water Resources, the on-site driller 2372  
 Signed Alma Laguna  
By driller performing actual drilling on site or contractor  
 Date 12/30/08