4

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107429
Permit No.
Basin 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63444

1. OWNER SFPP, L.P.
MAILING ADDRESS 1100 Town & Country Rd., Orange, CA 92868

ADDRESS AT WELL LOCATION 350 Galletti Way Reno, NV 89512
Subdivision Name: ~~S.T.~~ County: Washoe

2. LOCATION NE ¼ NW ¼ Sec 7 T 19 N/S R 20 E
PERMIT/WAIVER No. 0000762 Issued by Water Resources
3222078 Parcel No.

Latitude 39.32~~[illegible]~~.04 UTM E ☐ NAD 27
Longitude 119.46~~[illegible]~~.82 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand and gravels w/granite boulders in and out		0	30	30
SAME	X	30	66	36

~~N39.534223~~
~~W 119.779[illegible]27~~

N 39.534226
W 119.779345 NAD27

Date started: 12-21, 20 08
Date completed: 12-23, 20 08

7. Water Level
Static water level: 34 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEER'S OFFICE
2008 NOV 24 AM 11:50
RECEIVED

9. WELL CONSTRUCTION
Depth Drilled 66 Feet Depth Cased 65 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	66	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		Sch 40 PVC	0	65

Perforations:
Type of perforation PVC Screen
Size of perforation .020
From 30 feet to 65 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 25 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 28 to 66 ☐ Pumped ☒ Poured
Type: Monterey #3
Bentonite Chips: ☒ Yes ☐ No 25 to 28 ☐ Pumped ☒ Poured
Type: 3/8 Hole Plug

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (Contractor)
Address 3894 Railroad Ave. (Contractor)
Yuba City, CA 95991
Nevada contractor's license number issued by the State Contractor's Board 0021996
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2234
Signed (By driller performing actual drilling on-site or contractor)
Date 11-13-08

(Rev. 05-06) USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627