STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 107436

Permit No.

Basin 057

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62341

1. OWNER Craig Travis
MAILING ADDRESS PO Box 1592
Fallon, NV 89407-1592

ADDRESS AT WELL LOCATION Antelope Valley
Fallon, NV 89406
Subdivision Name: County: Lander

2. LOCATION SW¼SE¼ Sec36T25N/ R40E
PERMIT/WAIVER NO. 76845T
Issued by Water Resources Parcel. No.

Latitude 39.99017N UTM E ☐ NAD 27
Longitude -117.42120W N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	32	32
Brown Clay		32	55	23
Gravel w/Sand		55	72	17
Brown Clay		72	97	25
Large Gravel		97	101	4
Brown Clay		101	138	37
Clay w/Streaks & Gravel		138	150	12
Gravel	X	150	156	6
brown Clay		156	208	52
Large Gravel	X	208	215	7
Brown Clay		215	226	11
Large Gravel	X	226	235	9
Brown Clay		235	245	10
Gravel	X	245	249	4
Brown Clay		249	273	24
Gravel		273	276	3
Brown Clay		276	315	39

N39.990253
W 117.420259 NAD27

Date started: 10/27, 20 08
Date completed: 10/30, 20 08

9. WELL CONSTRUCTION

Depth Drilled 315 Feet Depth Cased 315 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
36 Inches	0 Feet	50 Feet
26 Inches	0 Feet	315 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30	39.05	.109	0	50
16	42.00	.250	0	315

Perforations:
Type of perforation Mill Cut
Size of perforation 1/4"
From 155 feet to 275 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 50 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 0 to 315 ☐ Pumped ☒ Poured
Type: Well Rock 3/4
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 110 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: cool °F
Quality: Unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Customer did own test pump		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling,Inc. (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2285
Signed By driller performing actual drilling on site or contractor
Date 11/5/2008

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com