WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 107479
Permit No.
Basin 179

NOTICE OF INTENT NO. 61755

1. OWNER Jerry Bowen
MAILING ADDRESS 3608 Frank Derek Ave.
Las Vegas, NV 89139

ADDRESS AT WELL LOCATION 5250 E. Robin Circle
Ely, NV 89301

2. LOCATION SE ¼ SE ¼ Sec. 32 T. 19 N/S R. 65 E. White Pine County
PERMIT NO. Issued by Water Resources | 10-840-13 Parcel No. | Duck Creek Subdivision Name

3. WORK PERFORMED
[XX] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[XX] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XX] Rotary [ ] RVC
[XX] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Rock & Boulders		3	10	7
Red Sandstone		10	95	85
Brown Clay w/ Gravel		95	110	15
Brown Sandstone		110	190	80
Altered Limstone		190	230	40
Brown Clay & Gravel		230	245	15
Altered Limestone		245	270	25
Fractured Limestone	x	270	290	20
Altered Limestone		290	370	80
Fractured Limestone	x	370	380	10
Altered Limestone		380	400	20

WGS 84
N39° 27', .976"
W114° 40', .623"

N39.466334
W 114.676189 NAD27

Date started October 6, 2008
Date completed October 24, 2008

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [XX] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	45	2

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10-5/8	0	400

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	400

Perforations:
Type perforation Factory
Size perforation 1/8" x 2 1/2" 6 Rows
From 280 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [XX] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [XX] Poured
Seal Type: [ ] Neat Cement [XX] Cement Grout [ ] Concrete Grout

Gravel Packed: [XX] Yes [ ] No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 235 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Ave. (Contractor)
Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed Rick Lewis By Jerold D. Christiansen
(By driller performing actual drilling on site or contractor)
Date November 25, 2008

STATE ENGINEER'S OFFICE
2008 DEC -1 AM 11:38
RECEIVED

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627