WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 107529
Permit No.
Basin 162

NOTICE OF INTENT NO. 33150

1. OWNER ARTHUR TURNER
MAILING ADDRESS 3481 W RAND LN
PAHRUMP, NV

ADDRESS AT WELL LOCATION 3481 W RAND LN

2. LOCATION SW 1/4 SE 1/4 Sec. 1 T 20S N/S R 52E E NYE County
PERMIT NO. Issued by Water Resources
28-432-22 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	46	46
CALICHE		46	52	6
CLAY		52	84	32
CALICHE	WB	84	87	3
CLAY		87	124	37
CALICHE	WB	124	131	7
CLAY		131	162	31
CALICHE	WB	162	178	16
CLAY		178	188	10
CALICHE	WB	188	200	12

WGS84
N 36 DEGREES 14.172
W 116 DEGREES 04.585

UCNR/DWR
RECEIVED
JAN 22 2009
LAS VEGAS OFFICE

Date started 1/16/2009 , 19__
Date completed 1/16/2009 , 19__

7. WELL TEST DATA
TEST METHOD: Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63.	.280	0	200

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 68 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address 1220 E MANSE RD Contractor
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed by driller performing actual drilling on-site or contractor
Date 1/19/2009

USE ADDITIONAL SHEETS IF NECESSARY