WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 107534
Permit No.
Basin 117

NOTICE OF INTENT NO. 34048

1. OWNER Roberto Miramontes
MAILING ADDRESS PO Box 147 Dyer NV 89010
ADDRESS AT WELL LOCATION Mile Marker # 9 HWY 264 Dyer NV 89010

2. LOCATION S/W ¼ N/W ¼ Sec. 15 T. 3 3 N/S 35 E. Esmerald County
PERMIT NO. (Issued by Water Resources) 00730136 (Parcel No.) 35E (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Small Gravle	No	0	21	21
Black Granite Rock	no	21	23	2
Brown Dirt	no	23	40	17
Assorted 3/8 Gravle	no	40	50	10
White sand tan clay	no	50	75	25
Brown clay & Gravle	no	75	94	19
Hard Black Basalt	no	94	98	4
Tan clay&Small				
Gravel	Yes	98	240	142

GPS37

GPS 37.44.556N
GPS 118 49.63W

DCNR/DWR RECEIVED
FEB 04 2009
LAS VEGAS OFFICE

Date started 9-19-08, 2008
Date completed 9-23-08, 2008

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
125	0	125	.5
150	30	150	.5
175	50	175	1
200	60	200	1
220	75	220	2

8. WELL CONSTRUCTION
Depth Drilled 240' Feet Depth Cased 229' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8 Inches	0 Feet	240 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.308	0	15
6"		.305	15	240

Perforations:
Type perforation Slot
Size perforation .0625"
From 89' feet to 229' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 119' feet below land surface
Artesian flow no G.P.M. 0 P.S.I.
Water temperature cool °F Quality clear good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Russell Kile
Contractor
Address 22893 HWY 6 Bishop CA 93514
Contractor

Nevada contractor's license number issued by the State Contractor's Board 039576

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1238

Signed Russell Kile
By driller performing actual drilling on site or contractor
Date 10-10-08

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (0)-027