STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107535
Permit No. 56351
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

W079

NOTICE OF INTENT NO. 33470

1. OWNER Las Vegas Valley Water Dist.
MAILING ADDRESS 1001 S. Valley View
Las Vegas NV 89153

ADDRESS AT WELL LOCATION 361 S Valley View Blvd
Las Vegas, NV 89153 - Well # 79
Subdivision Name: County:

2. LOCATION SE ¼ SW ¼ Sec 24 T 20 N/S R 61 E
PERMIT/WAIVER No. 56351 (Issued by Water Resources) 13929401001 (Parcel No)

Latitude 361028.74° N UTM E 663634.3125 NAD 27
Longitude 1151049.764° W N 4004853.75 NAD 83/WGS 84

29

3. WORKED PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Rehabilitation | | | | |
| by dual swab + | | | | |
| airlifting | | | | |
| Airlift well in all | | | | |
| screen sections to | | | | |
| remove sand + improve | | | | |
| production | | | | |

Date started: 3-3- , 20 08
Date completed: 3-14- , 20 08

7. Water Level
Static water level: 25 feet below land surface
Artesian Flow: NO G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

DCNR/DWR
RECEIVED
JAN 23 2009

9. WELL CONSTRUCTION
Depth Drilled 1280 Feet Depth Cased 1260 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 20" | | 3/8" | | |

Perforations:
Type of perforation Wire wrap screen
Size of perforation

| | | | |
|---|---|---|---|
| From 300 | feet to | 350 | feet |
| From 630 | feet to | 690 | feet |
| From 850 | feet to | 910 | feet |
| From 1140 | feet to | 1240 | feet |
| From | feet to | | feet |

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Layne Christensen (Contractor)
Address 11001 Etiwanda Ave. (Contractor)
Fontana, Ca 92337
Nevada contractor's license number issued by the State Contractor's Board 43608
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1648
Signed Willy Capt (By driller performing actual drilling on site or contractor)
Date 1-22-09

USE ADDITIONAL SHEETS IF NECESSARY

LAS VEGAS OFFICE

(NSPO 3-08)

(O) 627