STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107541
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33366

1. OWNER County of Clark (PK)
MAILING ADDRESS 500 South Grand Central Parkway
Las Vegas, NV 89101

ADDRESS AT WELL LOCATION Public Right of Way on Broadbent Blvd
Subdivision Name: Whitney Lift Station County: Clark

2. LOCATION NE¼ SE ¼ Sec 26 T 21S N/S R 62 E
PERMIT/WAIVER No. DW-1287 (Issued by Water Resources) 16129399002 Parcel No.

Latitude 36 05' 29.89" Longitude 115 01' 20.99"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE DW
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
See Attached Well Log #2				

Date started: 24-Oct , 20 08
Date completed: 24-Oct , 20 08

7. Water Level
Static water level: 12 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	6	3/8	0	30

Perforations:
Type of perforation machine slot
Size of perforation 0.032
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout 10 to 12 ☐ Pumped ☒ Poured

Gravel Pack: ☒ Yes ☐ No 12 to 30 ☐ Pumped ☒ Poured
Type: 3/8 Pea Gravel
Bentonite Chips: ☒ Yes ☐ No 10 to 12 ☐ Pumped ☒ Poured
Type: 3/8's

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Viking Drillers Inc (Contractor)
Address 801 Northport Dr. (Contractor)
West Sacramento, CA
Nevada contractor's license number issued by the *State Contractor's Board* 0034680
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* DEW-2361
Signed (By driller performing actual drilling on site or contractor)
Date 12/8/08

RECEIVED DEC 22 2008 LAS VEGAS OFFICE

(Rev. 06-08) **USE ADDITIONAL SHEETS IF NECESSARY**

THIS BORING LOG IS FOR VIKING'S ... RNAL PURPOSES ONLY. IT DOES NOT REPRESE... ...RMATION PROVIDED BY A SOILS ENGINEER.

LOG FOR BORING NO. 2		JOB NAME: Harbor			
DATE STARTED 10-24-08	DATE COMPLETED	LOGGED BY Ed	DRILLED BY Ed	TYPE OF DRILL RIG #32	JOB NO. 5939
DEPTH OF HOLE 30'	DIAMETER OF HOLE 24"	CASING 8"	PERFORATIONS 20'	SAMPLING METHOD	ELEVATION
LOCATION					

DEPTH	SAMPLES	GRAPHIC	DESCRIPTION
			SILT & Rock
			Backfill
10'			sand & gravel
			hard clay
20'			
			Cleach; hard pan
30'			
40'			
50'			
60'			
70'			
80'			
90'			
100'			

DRILLERS NOTES:

We Tryed To tap The man hole gravel, but The Line & man hole must be set in slurry. I drilled Past it - Next To it, and moved Tword it half a hole and hit slurry at 12' and worked out and down In to clay at 15'

N 36° 05' 29.89"

W 115° 01' 20.99

RECEIVED
DEC 2 2 2008
LAS VEGAS OFFICE