

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. _____
 Permit No. _____
 Basin 744

NOTICE OF INTENT NO. 30540

1. OWNER Robert Pennod ADDRESS AT WELL LOCATION 1 mile North of Elberz exit 317
 MAILING ADDRESS 255 11th Street Elko, Nv. 89801

2. LOCATION SW 1/4 Sec 33 T. 36 N/S R. 57 E Elko County
 PERMIT NO. 73059 Issued by Water Resources Parcel No. 006-550-013
 Subdivision Name NAD 27 40° 57.380' N 115° 32.924' W

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Topsoil		0	7	7
Sand, clay		7	21	
silt, sand		21	54	
clay		54	70	
silt, sand		70	110	
clay		110	119	
sand, gravel		119	174	
clay, sand		174	181	
silt, sand, gravel		181	240	
clay		240	245	

NAD 27
 40° 57.380' N
 115° 32.924' W
 N40.956226
 W115.548774 NAD27

8. WELL CONSTRUCTION
 Depth Drilled 245 Feet Depth Cased 245 Feet
 HOLE DIAMETER (BIT SIZE)
 From 15 Inches To 245 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	22	.250	+2	5
8	PVC	SDR 17	5	245

Perforations:
 Type perforation factory screen
 Size perforation .032 slot
 From 145 feet to 245 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 107 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 107 feet to 245 feet

9. WATER LEVEL
 Static water level 3.4' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 54 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Webber Drilling Contractor
 Address PO Box 40 Contractor
Overton, Nv.
 Nevada contractor's license number 25887
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2236
 Signed Bryan Anzalone
 By driller performing actual drilling on site or contractor
 Date Feb 18, 2008

Date started Jan 4, 2008
 Date completed Feb 15, 2008

7. TEST METHOD: Bailor Pump Air Lift
 G.P.M. 0.50 (Feet Below Static) _____ (Hours)
2009 APR - 3 PM
 RECEIVED 2 hrs