

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT**

**OFFICE USE ONLY**

Log No. 107578  
Permit No. \_\_\_\_\_  
Basin Φ 67

**PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK**

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63479

1. OWNER Glen Ryan ADDRESS AT WELL LOCATION 5857 Melarkey Way  
MAILING ADDRESS P.O. Box 19583 Reno, NV 89511  
5857 Melarkey Way, Reno NV 89511  
Subdivision Name: \_\_\_\_\_ County: Washoe

2. LOCATION NE ¼ SE ¼ Sec 26 T 18N N/S R 19 E Latitude 39.395947 UTM E  NAD 27  
PERMIT/WAIVER No. DOM07-021 150-250-01 Longitude 119.808960 N  NAD 83/WGS 84  
Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other x mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>boulders w/clay</u>		<u>152</u>	<u>300</u>	<u>148</u>

N 39.396036  
W 119.807938 NAD27

9. WELL CONSTRUCTION

Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>6 1/8</u> Inches	<u>152</u> Feet	<u>300</u> Feet
_____ Inches	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5 9/16</u>	<u>10.7</u>	<u>1.88</u>	<u>140</u>	<u>300</u>

Perforations:

Type of perforation factory mill slot  
Size of perforation 3/32"

From	feet to	feet to	feet to	feet to
<u>180</u>	<u>200</u>	<u>200</u>	<u>300</u>	<u>300</u>
<u>280</u>	<u>300</u>			

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured

Cement Grout to \_\_\_\_\_  Pumped  Poured

Concrete Grout to \_\_\_\_\_  Pumped  Poured

≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No to \_\_\_\_\_  Pumped  Poured

Type: \_\_\_\_\_

Bentonite Chips:  Yes  No to \_\_\_\_\_  Pumped  Poured

Type: \_\_\_\_\_

7. Water Level  
Static water level: 141 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: cold °F  
Quality: clear

8. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>159</u>	<u>4</u>
<u>10</u>	<u>19</u>	<u>1</u>
<u>10</u>	<u>19</u>	<u>1</u>

RECEIVED  
NOV 17 PM 12:37  
STATE ENGINEERS

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name McKay Drilling, Inc  
Contractor

Address 4850 Joule St. Suite A5  
Contractor

Reno, NV 89502

Nevada contractor's license number issued by the State Contractor's Board 14170

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 786

Signed Steve McKay  
By driller performing actual drilling on site or contractor

Date 11/11/2008