

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107586
Permit No. _____
Basin 249

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61424

1. OWNER Alec Goicoechea ADDRESS AT WELL LOCATION 1903 Canyon Road Mountain City Hwy
MAILING ADDRESS 1903 Canyon Road
NW Elko, NV 89801 Subdivision Name: _____ County: Elko

2. LOCATION 36 1/4 NW 1/4 Sec 7 T 34N N/S R 55 E Latitude 40.952370 UTM E 598698 NAD 27
PERMIT/WAIVER No. 083-002-016 Longitude 115.829094 N 4522817 NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Aluvium		0	150	150
Sandstone Clay		150	450	300
Clay		450	520	70
Sandstone, shale	590	520	660	140
Water Stratus				
10 gpm		590	620	30
20 gpm		620	640	20
35 gpm		640	660	20

9. WELL CONSTRUCTION

Depth Drilled 660 Feet Depth Cased 660 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10</u>	<u>0</u>	<u>660</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>1/4</u>	<u>0</u>	<u>660</u>

Perforations:

Type of perforation Plasma Cut
Size of perforation 1/8"

From	feet to	feet
<u>600</u>	<u>660</u>	

Annular Seal: Yes No

Material	to	to	Pumped	Poured
<input checked="" type="checkbox"/> Neat Cement	<u>0</u>	<u>50</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<input type="checkbox"/> Cement Grout			<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> Concrete Grout			<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> ≥30% Bentonite Grout			<input type="checkbox"/>	<input type="checkbox"/>

Gravel Pack: Yes No 50 to 660 Pumped Poured
Type: 1/4"

Bentonite Chips: Yes No to Pumped Poured
Type: _____

7. Water Level
Static water level: 420 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: 62 °F
Quality: Good

8. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>N/A</u>	<u>12</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eklund Drilling Company Contractor
Address PO Box 2748 Contractor
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1395

Signed George Adkins by [Signature]
by driller performing actual drilling on site or contractor

Date 11/3/2008