STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 107596

Permit No.

Basin 071

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62709

1. OWNER Gina Davenport

MAILING ADDRESS 3210 Ether Way - Winnemucca, NV

ADDRESS AT WELL LOCATION 3210 Ether Way Winnemucca, NV 89445

Subdivision Name: County: Humboldt

2. LOCATION NE ¼ SE ¼ Sec 24 T 35 N/ R 37 E

Latitude N40°89037 UTM E ☐ NAD 27

Longitude W117°75983 N ☒ NAD 83/WGS 84

PERMIT/WAIVER NO. 014-103-21

Issued by Water Resources Parcel. No.

3. WORK PERFORMED: ☐ New Well ☐ Replace ☐ Recondition ☒ Deepen ☐ Other

4. PROPOSED USE: ☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel	X	155	180	25
cobles		180	190	10
clay		190	200	10
cobles		200	205	5
sand/gravel	X	205	230	25
cobles		230	235	5
sand/gravel	X	235	255	20

N 40.896466
W 117.758867 NAD27

Deepening of log 67793

Date started: October 29, 20 08

Date completed: October 30, 20 08

7. Water Level

Static water level: 145 feet below land surface

Artesian Flow: N/A G.P.M. N/A P.S.I

Water Temperature: Cool °F

Quality: Good

8. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
22		4

9. WELL CONSTRUCTION

Depth Drilled 255 Feet Depth Cased 255 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 1/4 Inches	155 Feet	255 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	8	188	155	255

Perforations:

Type of perforation Factory Cut Slots

Size of perforation 3/32 X 4

From 215 feet to 255 feet

From feet to feet

From feet to feet

From feet to feet

From feet to feet

Annular Seal: ☐ Yes ☐ No

☐ Neat Cement Existed to ☐ Pumped ☐ Poured

☐ Cement Grout to ☐ Pumped ☐ Poured

☐ Concrete Grout to ☐ Pumped ☐ Poured

☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☐ Yes ☐ No Natural to ☐ Pumped ☐ Poured

Type:

Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured

Type:

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fred Anderson Drilling, Inc. (CONTRACTOR)

Address 10760 S. Grass Valley Road (CONTRACTOR)

Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 021467

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083

Signed Fred Anderson Drilling Inc

By driller performing actual drilling on site or contractor

RECEIVED 2008 NOV 10 PM 1:30 STATE ENGINEER'S OFFICE

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com