

Log No. \_\_\_\_\_  
 Permit No. \_\_\_\_\_  
 Basin **110B**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **57888**

1. OWNER **Hawthorn Army Depot** ADDRESS AT WELL LOCATION **rwj-21**  
 MAILING ADDRESS **1 S. main st Hawthorn NV 89415**

2. LOCATION **NW 1/4 SW 1/4 Sec. 32 T. 9 N/S R. 30 E Mineral** County  
 PERMIT NO. **N 1388808, 700 E 476723, 600** Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **Auger**

6. LITHOLOGIC LOG

| Material                  | Water Strata | From      | To        | Thick-ness |
|---------------------------|--------------|-----------|-----------|------------|
| <b>cement grout</b>       |              | <b>0</b>  | <b>15</b> | <b>15</b>  |
| <b>Filter pac</b>         |              | <b>15</b> | <b>35</b> | <b>20</b>  |
| <b>N 38.595230</b>        |              |           |           |            |
| <b>W 118.664780 NAD23</b> |              |           |           |            |

8. WELL CONSTRUCTION  
 Depth Drilled **35** Feet Depth Cased **35** Feet  
 HOLE DIAMETER (BIT SIZE)  
 From **10** Inches To **35** Feet  
 From **0** Feet To **35** Feet  
 From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
 From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <b>3</b>           | <b>JCED 40</b>      |                         | <b>0</b>    | <b>35</b> |

Perforations:  
 Type perforation **mill**  
 Size perforation **.010**  
 From **15** feet to **25** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **35**  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  
 Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level **dry** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **WDC** Contractor  
 Address **PO Box 141** Contractor  
**Zumora CA 95698**  
 Nevada contractor's license number issued by the State Contractor's Board **12852**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2111**  
 Signed **Jim W. Dutton**  
 By driller performing actual drilling on site or contractor  
 Date **2-14-08**

Date started **3/7**, 20**07**  
 Date completed **3/7**, 20**07**

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours)      |
|--------|-------------------------------|-------------------|
|        | <b>01:01:45</b>               | <b>0-00:00:00</b> |

RECEIVED  
 2008 JUN 20 AM 11:36  
 STATE ENGINEERS OFFICE