STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107637
Permit No.
Basin 088

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63535

1. OWNER RICH HARVEY GLORY TEMPLE CHURCH
MAILING ADDRESS 16255 S VIRGINIA ST
RENO NV 89521 17N

ADDRESS AT WELL LOCATION 16255 S. VIRGINIA ST
RENO NV 89521
Subdivision Name: County: Washoe

2. LOCATION NE ¼ NW ¼ Sec 4 ~~20~~ T ~~19N~~ N/S R 20 E
PERMIT/WAIVER No. 65090 (Issued by Water Resources) 045-210-01 (Parcel No.)

Latitude 39.37338*N
Longitude 119.747774*W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	3	3
FRACTURED GRAVELS		3	21	18
VOLCANIC SANDS		21	63	42
VOLCANIC GRAVELS		63	82	19
VERY FRACTURED VOLCANIC SANDS AND GRAVEL	XXX	82	120	38

~~N39.373469~~
~~W119.746722~~ NAD27

Date started: 19-Nov, 20 08
Date completed: 21-Nov, 20 08

9. WELL CONSTRUCTION
Depth Drilled 120' Feet Depth Cased 120' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
SDR 21	4.26	~~.216~~ .316	20	120

Perforations:
Type of perforation SAW CUT
Size of perforation 3X3/32
From 104 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 100 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 100 to 120 ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 64 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: WARM °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	23	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLINH AND PUMP SERVICE INC. (Contractor)
Address # 20 KIT KAT DRIVE (Contractor)
CARSON CITY NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 11/29/2008

(Rev. 06-08) USE ADDITIONAL SHEETS IF NECESSARY

2008 DEC 18 AM 10:51
RECEIVED
STATE ENGINEER'S OFFICE