

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61757

1. OWNER George Irlbeck ADDRESS AT WELL LOCATION 6075 E. 297 3rd N. st.
 MAILING ADDRESS HCR 33 Box 33905
Ely, NV 89301

2. LOCATION SE 1/4 ~~1/4~~ 1/4 Sec. 5 T. 25 N/S R. 65 E. White Pine Co. County
 PERMIT NO. SE 008-110-02 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, Silt, Gravel & Clay	x	0	145	145
Clay		145	355	210
Interbedded Sand, Gravel & Clay		355	370	15
Clay		370	400	30
Interbedded Sand & Clay		400	465	65
Sand, Gravel & Some Clay	x	465	650	185

N4D.069048
W 114.641688 NAD 27

RECEIVED
 2008 DEC 16 PM 1:43
 STATE ENGINEERS OFFICE

WGS 84
 N 40° 04' 08.3"
 W 114° 38' 33.2"
 Elevation 5,889

8. WELL CONSTRUCTION
 Depth Drilled 650 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)
 From 13 3/4 Inches To 650 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-5/8	22.36	.250	0	600

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 8 Rows
 From 300 feet to 600 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 ft. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 650 feet

9. WATER LEVEL
 Static water level 21 1/2 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 75 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Ave.
Ely, NV 89301 Contractor

Nevada contractor's license number 14790
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2259
 Division of Water Resources, the on-site driller

Signed Greg Tallia By Jerald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date December 12, 2008

Date started October 27, 2008
 Date completed November 19, 2008

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	150	579	11
	130	479	11
	128	379	11
	114	279	11
	98	179	11
	53	79	11