

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 107642
 Permit No. _____
 Basin 71

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63698

1. OWNER Brad & Lynda Wigglesworth ADDRESS AT WELL LOCATION 7245 Jackson Winnemucca, NV 89445
 MAILING ADDRESS 7245 Jackson Winnemucca, NV 89445

2. LOCATION NW¼NE¼ Sec13T35N / R37E Latitude N40°91190 UTM E _____ NAD 27
 PERMIT/WAIVER NO. 013-541-28 Longitude W117°76277 N _____ NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	3	3
Clay		3	15	12
Sand/Gravel		15	80	65
Cobles		80	95	15
Clay		95	100	5
Sand/Gravel	X	100	115	15
Boulders		115	150	35
Clay		150	170	20
Sand/Cobles	X	170	205	35
Clay		205	220	15

9. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 5/8 Inches 0 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	20
6.625	4	.316	20	220

Perforations:
 Type of perforation Factory Cut Slots
 Size of perforation 050
 From 180 feet to 220 feet
 From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement 0 to 45 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured
 Gravel Pack: Yes No 50 to 220 Pumped Poured
 Type: _____
 Bentonite Chips: Yes No 45 to 50 Pumped Poured
 Type: _____

Date started: November 24, 20 08
 Date completed: November 26, 20 08

7. Water Level
 Static water level: 118 feet below land surface
 Artesian Flow: N/A G.P.M. N/A P.S.I.
 Water Temperature: Cool °F
 Quality: Good

8. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M. <u>22</u>		<u>5</u>
<u>2008 DEC 15 PM 12:39</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson Drilling, Inc.
 (CONTRACTOR)

Address 10760 S. Grass Valley Road
 (CONTRACTOR)
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2082
 Signed Fred Anderson Drilling, Inc.
 By driller performing actual drilling on site or contractor
 Date December 10, 2008