STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107660
Permit No.
Basin 187

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61061

1. OWNER New West Gold, USA
MAILING ADDRESS 230 S. Rock Blvd
Reno, NV 89502

ADDRESS AT WELL LOCATION Long Canyon
MW-3 (from NOI) RC 4-14-09
Subdivision Name: County: Elko

2. LOCATION SW ¼ SW ¼ Sec 21 T 36N N/S R 66 E
PERMIT/WAIVER No. M/O-1508
Issued by Water Resources
Parcel No.

Latitude
Longitude
UTM E 708331 N 4539759
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Limestone		0	110	110
Limestone & Diorite		110	135	25
Limestone		135	415	280
Dolomite	640	415	720	305
Limestone		720	900	180
#8 Silica Based Gravel				
900 to 554				
3/8" Kwik Plug Chip				
854 to 0				
N40.942493				
W 114.522768 NAD27				

Date started: 21-Nov, 20 08
Date completed: 3-Dec, 20 08

9. WELL CONSTRUCTION
Depth Drilled 900 Feet Depth Cased 900 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.5	Inches	0	Feet	20	Feet
6.5	Inches	20	Feet	900	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625		.25	0	20
2.375		Sch 80	+2	900

Perforations:
Type of perforation Slotted
Size of perforation 0.2
From 900 feet to 860 feet
From 860 feet to +2 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 10 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 900 to 854 ☐ Pumped ☒ Poured
Type: #8 Silica Based Gravel & Natural Fill
Bentonite Chips: ☒ Yes ☐ No 854 to 10 ☐ Pumped ☒ Poured
Type: 3/8" Kwik Plug Medium Chip

7. Water Level
Static water level: 497 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
14	N/A	1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc. (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2363
Signed Timothy Dawson by (MO) (By driller performing actual drilling on site or contractor)
Date 12/11/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

Plugged by weld log 122716