WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 107661
Permit No.
Basin 049

NOTICE OF INTENT NO. 54850

1. OWNER Salvador Rivera
MAILING ADDRESS 122 Park Road
ELKO, NV. 89801 -4377

ADDRESS AT WELL LOCATION 4084 Pueblo AVE.
ELKO, NV. (NAD-27 11T 0608266
4529627

2. LOCATION NW ¼ NW ¼ Sec. 19 T. 35 N/S R. 56 E/W ELKO County
PERMIT NO. Issued by Water Resources 036-003-004 Parcel No. Meadow Valley Ranchos #4 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0'	2'	2'
Gravel and CLAY		2'	80'	78'
Fine Gravel-Hard		80'	260'	180'
Fine Gravel-Soft		260'	315'	55'
N 40.912495				
W 115.714424 NAD27				
First water	198'			
more water	220'			
10 GPM	260'			
30 GPM	315'			
Gravel Pack- 55' to 315'				
3/8" Bentonite chips 55' to 25'				
Neat Cement 25' to -4				

Date started 11-25 —, 2008
Date completed 12-2 —, 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	6-330	4

8. WELL CONSTRUCTION
Depth Drilled 315' Feet Depth Cased 315' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	0'	315'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2'	275'
6.625	13 Perf.	.188	275'	315'

Perforations:
Type perforation 6 Row Perf.
Size perforation 3/16 X 3"
From 275' feet to 315' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal -4 to 25'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55' feet to 315' feet

9. WATER LEVEL
Static water level 161' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ward Weaver / Rim Rock Contractor
Address 2305 Last Chance Rd. Contractor
ELKO, NV. 89801
Nevada contractor's license number issued by the State Contractor's Board 0030630
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1676
Signed Ward Weaver By driller performing actual drilling on site or contractor
Date Dec. 3 2008

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627