STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 10769
Permit No.
Basin Ø49

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62607

1. OWNER Jerry Vega
MAILING ADDRESS 688 Kittridge #1
Elko, NV 89801

ADDRESS AT WELL LOCATION Antler Road Lot 20
Subdivision Name: MVR#5 County: Elko

2. LOCATION NE ¼ SE ¼ Sec 34 T 35N N/S R 55 E
PERMIT/WAIVER No. 006-10B-020
Issued by Water Resources Parcel No.

Latitude 40.52.583
Longitude 115.45.558
UTM E
N AD83
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Subsoil		0	16	16
Conglomerate Gravel		16	48	32
Sandstone		48	142	94
Soft Sand	X	142	148	6
Sandstone		148	174	26
Soft Sand	X	174	176	2
Sandstone		176	219	43
Sand & Gravel	X	219	221	2
Sandstone		221	234	13
Gravel & Sand	X	234	235	1
Sandstone		235	242	7
Gravel & Sand	X	242	260	18

N40.826478
W115.758390 NAD27

Date started: September 22, , 20 08
Date completed: September 24, , 20 08

9. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	260	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	19
6	PVC	SDR-17	19	260

Perforations:
Type of perforation screen
Size of perforation 0.032
From 220 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 19 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 51 to 260 ☐ Pumped ☒ Poured
Type: 3/8 Pea Gravel
Bentonite Chips: ☒ Yes ☐ No 19 to 50 ☐ Pumped ☒ Poured
Type: 3/4 Kiwk Plug

7. Water Level
Static water level: 30 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	60		4.5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sharel C. Fertig Sr., dba Fertig Drilling Co.
Contractor
Address P.O. Box 525
Contractor
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 031904
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1584
Signed
By driller performing actual drilling on site or contractor
Date 10-14-08

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY