

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34755


1. OWNER PALM MORTUARY, INC ADDRESS AT WELL LOCATION 1238 N. MAIN
MAILING ADDRESS 7600 So. EASTERN AVE LV, NV, 89101
LV, NV, 89123
2. LOCATION SE 1/4 NE 1/4 Sec. 27 T. 20 N/S R. 61 E CLARK County
PERMIT NO. WAIVER #R-1448139-27-603-001 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Air Lift Debris out of Hole with Air + foam - Debris was bottles, toys + old coffee maker, rocks + sand. Water flowed about 5 GPM.				
Cemented through Tremie pipe from bottom up with 24 sack cement slurry. 2 yds - 80 ft. 8" dia steel pipe.				
N36-11-02.6				
W115-08-12.7 NAD 27				
				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	Feet
From	To	
_____	_____	_____
_____	_____	_____
_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation _____
Size perforation _____

From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal _____ Neat Cement
Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL

Static water level Flow _____ feet below land surface
Artesian flow 5 GPM _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality _____

Date started 03-02-09, 20 _____
Date completed 03-04-09, 20 _____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick Contractor
Address 5360 N. Bonita Vista St. Contractor
LV, NV, 89149

Nevada contractor's license number issued by the State Contractor's Board. 10062

Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 552

Signed V. H. Dimick
By driller performing actual drilling on site or contractor

Date 03-04-09