

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33157

1. OWNER LANCE KRIEGH & PATRICIA BAIN ADDRESS AT WELL LOCATION WHITE BLVD
 MAILING ADDRESS WHITE BLVD
CRYSTAL, NV

2. LOCATION NW 1/4 SW 1/4 Sec. 31 T S16 N/S R E52 E NYE County
 PERMIT NO. 21-421-38 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & GRAVEL		0	15	15
GRAVEL & CLAY		15	80	65
SAND & GRAVEL	WB	80	91	11
CLAY & SAND		91	140	49
LIMESTONE	WB	140	160	20
GRAVEL	WB	160	200	40

WGS84
 N 36° 30' 57.1"
 W 116° 10' 49.1"

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>12</u>	<u>0</u>	<u>60</u>	<u>0</u>	<u>60</u>
<u>10.25</u>	<u>60</u>	<u>200</u>	<u>60</u>	<u>200</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>3.63</u>	<u>.280</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3

From	To	Feet	Feet
<u>140</u>	<u>200</u>	<u>140</u>	<u>200</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address 1220 E MANSE RD Contractor
PAHRUMP, NV. 89048

Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas D...
 By driller performing actual drilling on-site or contractor

Date 3/17/2009

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

Date started 3/16/2009 _____, 19
 Date completed 3/17/2009 _____, 19