

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 107722
 Permit No. 63611
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **33160**

1. OWNER **PAHRUMP TOWN** ADDRESS AT WELL LOCATION **1600 E HONEYSUCKLE ST**
 MAILING ADDRESS **1600 E HONEYSUCKLE ST**
PAHRUMP, NV

2. LOCATION SW 1/4 NE 1/4 Sec. 23 T 20S N/S R 53E E NYE County
 PERMIT NO. 63611 Issued by Water Resources Parcel No. 38-561-03 **CALVADA VALLEY UNIT 6** Subdivision Name


3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
VIDEO WELL AND FOUND HOLE IN CASING @ 230FT. WELL HAD FILLED IN TO 270 FT. WE CLEANED WELL OUT AND INSTALED 8" .188 WALL STEEL CASING AS A LINER 420 TO SURFACE.				
N 36° 11' 52.6"				
W 115° 59' 07.2"				
EXISTING WELL LOG # 73698				
<i>36.197979° N</i>				
<i>115.984471° W</i>				
<i>N 80 27 (T2)</i>				



8. WELL CONSTRUCTION
 Depth Drilled **EXISTING** Feet Depth Cased **425** Feet

HOLE DIAMETER (BIT SIZE)
 From To
EXST 10" Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42.05	.250	0	55
10.75	28.04	250	0	425
8 5/8	17.64	188	0	420

Perforations:
 Type perforation **SAW**
 Size perforation **1/8 X 3 X 8**

From	feet to	feet
	100	420
	feet to	feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **EXISTING** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **420** feet

Date started **3/31/2009**, 19
 Date completed **4/2/2009**, 19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	

9. WATER LEVEL
 Static water level **64** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.**
 Contractor
 Address **1220 E MANSE RD**
 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board **47333**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1426**
 Signed *[Signature]*
 By driller performing actual drilling on-site or contractor
 Date **4/3/2009**