STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107735
Permit No.
Basin 089

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62917

1. OWNER DAVID VHAY
MAILING ADDRESS 5440 EAST LAKE BLVD
SW WASHOE VALLEY, NV 89704

ADDRESS AT WELL LOCATION 5465 EAST LAKE BLVD
WASHOE VALLEY, NV 89704
Subdivision Name: County: Washoe

2. LOCATION SE ¼ SE ¼ Sec T 16N N/S R 20 E
PERMIT/WAIVER No. NW 16 50-351-56
Issued by Water Resources Parcel No.

Latitude 39.25478°N
Longitude 119.75118°W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 6 5/8 WELL		+2	190	188
COURSE DG SANDS		190	213	23
HARD BLUE GRANITE		213	228	15
RUSTY DG GRANITE	XXX	228	260	32
LOOSE				

N 39.254869
W 119.750164 NAD27
Deepening of log 28266

Date started: 10-Oct , 20 08
Date completed: 13-Oct , 20 08

9. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	inches	190	Feet	260	Feet
	inches		Feet		Feet
	inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
SDR 21	3.97	.316	180	260

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation 0.032
From 220 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement N/A to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 80 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	60	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address # 20 KIT KAT DRIVE
Contractor
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1905
Signed
by driller performing actual drilling on site or contractor
Date 10/15/2008

(Rev. 05-08) USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED
2008 NOV -4 AM 11:19
ENGINEERS OFFICE