

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34757

1. OWNER McKNIGHT SENIOR VILLAGE 11 LP ADDRESS AT WELL LOCATION 721 EFFINGER
Blvd, LV. NV. 89101
 MAILING ADDRESS 2655 S. RAINBOW
Blvd, LV. NV. 89142
 2. LOCATION SW 1/4 SW 1/4 Sec. 25 T. 20 N/S R. 61 E. CLARK County
 PERMIT NO. 139-25-410-043 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Pull Pump				
Perforate from 80F up to top				
Tried to pull casing				
No cement found				
Cased only to 80 FT 12" steel				
open hole to 250 FT 10"				
No casing				
Cement from bottom to top.				
24 sack neat cement.				
Static water 20 FT				
N 36' 10" 33.7"				
W 115' 06" 44.0" NAD 27				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	Feet
From _____	To _____	_____
_____	_____	_____
_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation _____
 Size perforation _____

From	feet to	feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 4-13-09 20 _____
 Date completed 4-15-09 20 _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR RECEIVED
 APR 16 2009

9. WATER LEVEL

Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VERNON H. DIMICK Contractor
 Address 5360 N. BONITO VISTA ST. LV. NV. 89149 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed V. H. Dimick By driller performing actual drilling on site or contractor
 Date 04-16-09