STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107782
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62841

1. OWNER SUSAN CLARIDGE
MAILING ADDRESS SIX MILE RANCH, HC61, BOX 210
WENDOVER, UT 84083-9601

ADDRESS AT WELL LOCATION END OF HONDO
Subdivision Name: PARCEL OF LAND County: ELKO

2. LOCATION SW ¼ SW ¼ Sec 17 T 34N N/S R 55 E
PERMIT/WAIVER No. ~~69748~~ 006-09F-018
69713, Issued by Water Resources 69714, 69715 Parcel No.

Latitude 40.828370
Longitude 115.811349
UTM E 11T 0600230 [X] NAD 27
N 4520173 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [X] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL DIRT		0	1	1
COURSE TAN GRAVEL		1	10	9
RED/BRN GRAVEL W/CLAY		10	80	70
TAN GRAVEL W/CLAY		80	90	10
RED/BRN GRAVEL W/CLAY		90	220	130
FINE RED GRAVEL	X	220	240	20
FINE RED & GRAY GRAVEL	XX	240	280	400
COURSE RED/GRAY GRAVEL	XXX	280	300	20
FINE RED/BRN GRAVEL	XXXX	300	360	60
1ST WATER 230'				
2ND WATER - 260'				
3RD WATER - 280'				
MORE WATER THE DEEPER				
THE HOLE WENT				
THE TEST HOLE WAS				
ABANDONED WITH BENTONITE				
GROUT PUMPED FROM THE				
BOTTOM OF THE HOLE				

Date started: 17-Sep, 20 08
Date completed: 19-Sep, 20 08

9. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	360	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
		N/A		

Perforations:
Type of perforation N/A
Size of perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [ ] Yes [ ] No
[X] Neat Cement 0 to 10 [X] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[X] ≥30% Bentonite Grout 20 to 360 [X] Pumped [ ] Poured
Gravel Pack: [ ] Yes [X] No to [ ] Pumped [X] Poured
Type:
Bentonite Chips: [X] Yes [ ] No 10 to 20 [X] Pumped [ ] Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: ~~[illegible]~~ UNK feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
250+		.5

STATE ENGINEERS OFFICE
2008 OCT 30 AM 11:41
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1653
Signed Jerry C. Benes (By driller performing actual drilling on site or contractor)
Date 10/3/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY