STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107800
Permit No.
Basin 048

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62845

1. OWNER KURT CRISS
MAILING ADDRESS 729 COTTONWOOD DRIVE
ELKO, NV 89801

ADDRESS AT WELL LOCATION ANDYS WAY
Subdivision Name: PARCEL OF LAND County: ELKO

2. LOCATION NE ¼ NW ¼ Sec 36 T 34N N/S R 55 E
PERMIT/WAIVER No. 006-090-041
Issued by Water Resources Parcel No.

Latitude 40.793283
Longitude 115.731827
UTM E 11T 606992 [X] NAD 27
N 4516372 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
GRAVEL & HARD SANDSTONE		2	5	3
MED/HARD BRN SANDSTONE		5	40	35
GREY SANDSTONE		40	100	60
GREY SANDSTONE	XX	100	200	100

Date started: 17-Oct, 20 08
Date completed: 17-Oct, 20 08

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		SDR-21 PLASTEC	20	200
6.625	13	.188 STEEL	+2	20

Perforations:
Type of perforation FACTORY SCREEN SDR-21
Size of perforation 1/0/1900
From 140 feet to 160 feet
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 5 to 15 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 55 to 200 [ ] Pumped [X] Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 15 to 55 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 63 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1

STATE ENGINEER'S OFFICE
2008 OCT 30 AM 11:41
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1166
Signed (By driller performing actual drilling on site or contractor)
Date 10/28/2008

(Rev. 06-06)

USE ADDITIONAL SHEETS IF NECESSARY