STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107808
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32095

1. OWNER Capital Coml Holdings LLC TBM Properties LLC
MAILING ADDRESS 6399 Wilshire Blvd
Los Angeles CA 90048

ADDRESS AT WELL LOCATION 352 Nellis Blvd
MW-9 Las Vegas NV 89110
Subdivision Name: County:

2. LOCATION NW ¼ SW ¼ Sec 33 T 20l N (S) R 62 E
PERMIT/WAIVER No. 140-33-301-005
Issued by Water Resources Parcel No.

Latitude 36 09931
Longitude 115 03711
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other ☒ auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	4"	#####
Sand&Gravel		4"	2	#####
Brown silty clay	17	2	25	23

DCNR/DWR
RECEIVED
FEB 19 2009
LAS VEGAS OFFICE

Date started: 18-Feb, 20 09
Date completed: 18-Feb, 20 09

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 24 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	10.79	.237	0	24

Perforations:
Type of perforation factory slotted
Size of perforation .020
From 9 feet to 24 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 8 to 25 ☐ Pumped ☐ Poured
Type: #3 silica sand
Bentonite Chips: ☒ Yes ☐ No 1 to 8 ☐ Pumped ☐ Poured
Type: 3/8 chips

7. Water Level
Static water level: 16 feet below land surface
Artesian Flow: n/a G.P.M. n/a P.S.I.
Water Temperature: n/a °F
Quality: good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
serge block			15 min

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 570 Corinthian way
Contractor
N Las Vegas NV 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M2371
Signed
By driller performing actual drilling on site or contractor
Date 2/19/2009

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY