STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107824
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

1. Clark County (Aviation)
PO Box 11005
Lasvegas, NV 89111-1005

33541
5164 RENT A CAR
Clark

2. SE NW 27 21 61
162-27-201-005
36.0960495
115.149
784340.4 ☐
26736868 ☐

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MW-14

Material		From	To	Thickness
Asphault		.0	.5	.5
Type II		.5	2	2
sand w/ gravel		2	9	7
caliche		9	11	2
gravel w/sand	18	11	25	14
clay		25	30	5

Oct 22 .20 08
Oct 22 .20 08

9. Depth Drilled 30' Feet Depth Cased 30' Feet

		From	To
9"	Inches	0 Feet	30' Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	PVC	Sch 40	0'	30

Type of perforation: Factory slot
Size of perforation: .020
From 10 feet to 30' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☒ Concrete Grout	1 to 6		☐ Pumped	☒ Poured
☐ ≥30% Bentonite Grout	to		☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 8 to 30 ☐ Pumped ☒ Poured
Type: #3 sand
Bentonite Chips: ☒ Yes ☐ No 6 to 8 ☐ Pumped ☒ Poured
Type: Hole plug

7. 18 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc. Contractor
Address 4255 W. Postal Contractor
Las vegas, NV 89118
Nevada contractor's license number 0054931
issued by the
Nevada driller's license number issued by the M-1869
Division of Water Resources, the
By driller performing actual drilling on site or contractor
11/4/08

USE ADDITIONAL SHEETS IF NECESSARY

DCNR/DWR
RECEIVED
NOV 12 2008
LAS VEGAS OFFICE