STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107879
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Lucky Champ
MAILING ADDRESS 1420 W.Bonanza Rd
Las Vegas NV 89106

NOTICE OF INTENT NO. 34988
ADDRESS AT WELL LOCATION Same As Owner
Subdivision Name:
County: Clark

2. LOCATION NW ¼ SE ¼ Sec 21 T 20S N/S R 61 E
PERMIT/WAIVER No. 13928703008
Issued by Water Resources
Parcel No.

Latitude 36.17756 W
Longitude 115.16025 W
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other (AUGER)

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	6"	
Fill Sandy Clay		6"	3'	
Sand w/Clay		3	8	
Sand w/Gravel		8	11	
Caliche		11	13	
Clay w/Sand		13	19	
Sandy Silt		19	26	
Sandy Clay		26	32'	

Date started: 4-Ap , 20 08
Date completed: 4-Ap , 20 08

9. WELL CONSTRUCTION
Depth Drilled 32 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9	Inches	0	Feet	32	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		Sch 40	10	Surface

Perforations:
Type of perforation Factory Slotted
Size of perforation 0.02
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 8 to 32 ☐ Pumped ☒ Poured
Type: Colorado Silica Sand 8-12
Bentonite Chips: ☒ Yes ☐ No 0 to 8 ☐ Pumped ☒ Poured
Type: Medium Chips

7. Water Level
Static water level: 15.76 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

CONTRACTOR RECEIVED APR 2 8 2008 LAS VEGAS OFFICE

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 570 Corinthian Way
Contractor
Las Vegas, NV 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2057-T3
Signed
By driller performing actual drilling on site or contractor
Date 4-28-08

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY