STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107881
Permit No.
Basin 212

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 34988

1. OWNER Lucky Champ
MAILING ADDRESS 1420 W.Bonanza Rd
Las Vegas NV 89106

ADDRESS AT WELL LOCATION Same As Owner
Subdivision Name: County: Clark

2. LOCATION NW ¼ SE ¼ Sec 21 T 20S N/S R 61 E
PERMIT/WAIVER No. 13928703008
Issued by Water Resources Parcel No.

Latitude 36.17750 N
Longitude 115.16054 W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other (AUGER)

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Asphalt | | 0 | 6" | |
| Fill Sand w/Gravel | | 6 | 3' | |
| Sandy Clay | | 3 | 9 | |
| Clay w/Small Gravel | | 9 | 12 | |
| Caliche | | 12 | 13 | |
| Clay w/Sand | | 13 | 20 | |
| Sandy Clay | | 20 | 31' | |

Date started: 4-Ap , 20 08
Date completed: 4-Ap , 20 08

7. Water Level
Static water level: 18.88 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

9. WELL CONSTRUCTION
Depth Drilled 31 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 9 | Inches | 0 | Feet | 31 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.5 | | Sch 40 | 10 | Surface |
| | | | | |
| | | | | |

Perforations:
Type of perforation Factory Slotted
Size of perforation 0.02
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 8 to 31 ☐ Pumped ☒ Poured
Type: Colorado Silica Sand 8-12
Bentonite Chips: ☒ Yes ☐ No 0 to 8 ☐ Pumped ☒ Poured
Type: Medium Chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 570 Corinthian Way
Contractor
Las Vegas, NV 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2057-T3
Signed
By driller performing actual drilling on site or contractor
Date 4-28-08

(Rev. 05-06)

**USE ADDITIONAL SHEETS IF NECESSARY**

APR 2 8 2008
LAS VEGAS OFFICE