

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY

Log No. 107921  
Permit No. \_\_\_\_\_  
Basin 179

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33482

1. OWNER Robinson Nevada Mining Company ADDRESS AT WELL LOCATION Step toe Valley Basin 179  
MAILING ADDRESS PO BOX 382 RNMN Ruth, NV (RIBX-1)(WDB-1)  
Ruth, NV 89139 Subdivision Name: \_\_\_\_\_ County: White Pine

2. LOCATION NW 1/4 NW 1/4 Sec 33 T 17N N/S R 62 E Latitude 672209 UTM E N 39 300571  NAD 27  
PERMIT/WAIVER No. M/O 1511 Longitude 4351825 N N 115 002909  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  Domestic  Irrigation  Test  Stock  
 Municipal/Industrial  Monitor

5. WELL TYPE  Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine Sands		0	20	20
Sands and Gravels		20	80	60
Clayey		80	85	5
Sands and Gravels		85	100	15
Fine Sands		100	110	10
Sands and Gravels		110	150	40
Reddish Sandsand Gravel		150	160	10
*Rapid Infiltration basin well. Casing not to total depth.				
4"Casing was pulled prior to abandonment				
Abandonment done on 9/4/08				

9. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 50 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>9 5/8</u> Inches	<u>0</u> Feet <u>160</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>10.79</u>	<u>.237</u>	<u>+3</u>	<u>30</u>

Perforations:

Type of perforation Factory Slotted  
Size of perforation 0.05

From 30 feet to 50 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 25 to 50  Pumped  Poured  
Type: 8x12

Bentonite Chips:  Yes  No 50 to 160  Pumped  Poured  
Type: Medium

7. Water Level

Static water level: Dry feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WDC Exploration & Wells  
Contractor

Address 570 Corinthian Way  
Contractor

N. Las Vegas, NV 89030

Nevada contractor's license number  
issued by the State Contractor's Board 0012852

Nevada driller's license number issued by the  
Division of Water Resources, the on-site driller 2057

Signed [Signature]  
By driller performing actual drilling on site or contractor

Date 10/2/2008