WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 107938
Permit No.
Basin 179

NOTICE OF INTENT NO. 61758

1. OWNER Jesse Murdock
MAILING ADDRESS 207 East Grant Ave. Ely, NV 89301
ADDRESS AT WELL LOCATION 207 East Grant Ave. Ely, NV 89301

2. LOCATION NE ¼ NW ¼ Sec. 23 T. 16 N/S R. 63 E. White Pine County
PERMIT NO. 33203 (Issued by Water Resources) 10-500-07 (Parcel No.) Pearce (Subdivision Name)

3. WORK PERFORMED
[X] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Sand & Gravel		3	40	37
Clay & Gravel		40	120	80
Water Bearing Gravel	x	120	122	2
Clay & Gravel		122	168	46
Water Bearing Gravel	x	168	170	2
Clay w/ Gravel Stringers		170	240	70
Course Water Gravel	x	240	250	10
Brown Clay		250	260	10

N39,947676
W 114,853220 NAD27

WGS 84
N39° 14' 33.4"
W114° 51' 14.7"

Date started November 18, 20 08
Date completed November 26, 20 08

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
80	149	1 1/2

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10-5/8	0	260

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	260

Perforations:
Type perforation Factory
Size perforation 1/8" x 2-1/2" 6 Rows
From 100 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 ft.
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 101 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Ave. Ely, NV 89301 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2259
Signed Greg Gallio By Jerald D. Christiansen (By driller performing actual drilling on site or contractor)
Date December 29, 2008

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627