STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 10808
Permit No.
Basin Ø88

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63140

1. OWNER Harry Fry
MAILING ADDRESS 17300 Majestic View Dr.
Reno, NV 89521

ADDRESS AT WELL LOCATION 17300 Majestic View Dr.
Reno, NV 89521
Subdivision Name: County: Washoe

2. LOCATION NW ¼ SE ¼ Sec 3 T 17N N/S R 20 E
PERMIT/WAIVER No. 050-520-48
Issued by Water Resources Parcel No.

Latitude 39 364 54
Longitude 119 720 74
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
fractured rock		245	418	
Deepening of log 99778				
N39.364629				
W 119.719723 NAD27				
Log was originally				
received on 12/30/2008				

Date started: 12-Aug, 20 08
Date completed: 15-Aug, 20 08

7. Water Level
Static water level: 171 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	229	2.5 hrs.
30	129	30 min.
20	79	30 min.
6	29	10 min.

9. WELL CONSTRUCTION
Depth Drilled 418 Feet Depth Cased 418 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	245	Feet	418	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 9/16	10.7	.188	238	418

Perforations:
Type of perforation factory mill slot
Size of perforation 3/32
From 258 feet to 298 feet
From 318 feet to 338 feet
From 378 feet to 418 feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling, Inc (Contractor)
Address 4850 Joule St. Suite A5 (Contractor)
Reno, NV 89502
Nevada contractor's license number issued by the *State Contractor's Board* 14170
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 786
Signed Steve McKay (By driller performing actual drilling on site or contractor)
Date 8/22/2008

(Rev. 06-08)

USE ADDITIONAL SHEETS IF NECESSARY