

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108027
Permit No. _____
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

N40960792 W17.746750 N1027

1. OWNER Elite Drilling Inc.
MAILING ADDRESS 333 W. Center Street
N. Salt Lake, Utah 84054

ADDRESS AT WELL LOCATION 1880 W. Winnemucca Blvd.
Winnemucca, Nevada
Subdivision Name: _____ County: Humboldt

2. LOCATION SE 1/4 SW 1/4 Sec 38 T 36 N R 38 E
PERMIT/WATER No. 15-242-08
Parcel No. _____

Latitude N 40° 57' 36.47" UTM E NAD 27
Longitude W 117° 44' 57.79" N NAD 83/WGS 84
Facility # E-000971 SP-1

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Asphaltic Concrete</u>		<u>0</u>	<u>1/2</u>	<u>1/2</u>
<u>Sand w/ silt, gravel</u>	<u>wet</u>	<u>1/2</u>	<u>15 1/2</u>	<u>15</u>
		<u>15 1/2</u>	<u>32</u>	<u>16 1/2</u>

9. WELL CONSTRUCTION

Depth Drilled	<u>32 1/2</u>	Feet	Depth Cased	<u>32 1/2</u>	Feet
---------------	---------------	------	-------------	---------------	------

HOLE DIAMETER (BIT SIZE)

	From	To
<u>8</u>	<u>0</u>	<u>32 1/2</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>sch. 40</u>	<u>ASTM F-480</u>	<u>0</u>	<u>32 1/2</u>

Perforations:
Type of perforation Factory Slots
Size of perforation 020
From 30 feet to 32 1/2 feet

Annular Seal: Yes No
 Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout 0 to 12 Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 29 to 32 1/2 Pumped Poured
Type: #3 Monterey Sand
Bentonite Chips: Yes No 12 to 29 Pumped Poured
Type: 3/8 Bentonite Hole Plug

Date started: 7-24, 2008
Date completed: 7-24, 2008

7. Water Level
Static water level: 15.3 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
		<u>NA</u>	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc.
Address 4255 W. Post Rd.
Las Vegas, Nevada 89118
Nevada contractor's license number 054931
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 191944
Signed Thomas Beall
By driller performing actual drilling on-site or contractor
Date 7-30-08