

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



office use only
Log No. 108037
Permit No.
Basin 087

NOTICE OF INTENT NO 58982

1. OWNER **Richard Edwards** ADDRESS AT WELL LOCATION **La Sale Heights**
MAILING ADDRESS **249 Caliente St** Latitude N 39.51583
Reno, NV 89509 Longitude W 119.90785 WGS84
2. Location **SW 1/4 NE 1/4** Sec **13 T 19 N R 18 E** **Washoe** County
PERMIT NO. PARCEL NO. **039-131-32** SUBDIVISION NAME **Mesa Park**

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	<input type="checkbox"/> Cable	<input checked="" type="checkbox"/> Rotary	RVC
Deepen	Abandon	Other	Municipal/Industrial	Monitor	Stock	<input checked="" type="checkbox"/> Air	Other	Mud

6. LITHOLOGIC LOG					8. WELL CONSTRUCTION					
Material	Water/Strata	From	To	Thickness	Depth Drilled	HOLE DIAMETER (BIT SIZE)	Depth Cased	From	To	
Boulders		0	10	10	10 5/8	inches	0	feet	238	feet
DG and Grey Clay		10	40	30		inches		feet		feet
Grey Clay and Gravel		40	100	60		inches		feet		feet
Grey Clay		100	150	50	CASING SCHEDULE					
Grey Clay and Gravel		150	195	45	Size O.D. Weight/Ft. Wall Thickness From To					
Brown Clay		195	200	5	(Inches) (Pounds) (Inches) (Feet) Feet					
Broken Rock	x	200	238	38	6 5/8 12.97 .188 0 102					
				0						
				0						
				0	Perforations::					
				0	Type Perforation	Factory				
				0	Size perforation	3/32				
				0	From	198	feet to	238	feet	
				0	From		feet to		feet	
				0	From		feet to		feet	
				0	From		feet to		feet	
				0	From		feet to		feet	
				0	From		feet to		feet	
				0	Surface Seal	x YES	No	Seal Type:		
				0	Depth of Seal	100	feet	Neat Cement		
				0			Pumped	<input checked="" type="checkbox"/> Cement Grout		
				0			x Poured	Concrete Grout		
				0	Gravel Packed:	x Yes	No			
				0	From	100	feet to	238	feet	
				0						
				0	9 WATER LEVEL					
				0	Static water level	170	feet below land surface			
				0	Artesian flow	GPM	0	P.S.I.		
				0	Water Temperature	cold	Degrees F	Quality good		

N 39.515940
W 119.906842 NA027

Date started **9/16 -06**
Date completed **9/20 -06**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)	
25	65	1	
10	30		
5	10		

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**
4850 Joule St.
Reno, NV 89502

NV Contractors No. **14170**
NV Driller's Lic (on site) **2187**

Signed *Steve McKay*
By driller performing actual drilling on site or contractor

Date **9/20 -06**