STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108047
Permit No.
Basin Ø42

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62600

1. OWNER Kevin Watt
MAILING ADDRESS P.O. Box 727
SE Wendover, UT 84083

ADDRESS AT WELL LOCATION Golden Eye Ave
Unit 1, Block 9, Lot 7
Subdivision Name: County: Elko

2. LOCATION SW ¼ NW ¼ Sec 11 T 36N N/S R 58 E
PERMIT/WAIVER No. 018-009-007
Issued by Water Resources Parcel No.

Latitude N41.01.336
Longitude W115.24.222
UTM E N NAD 84
☐ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam		0	1	1
Sandy Loam		1	58	57
Blue Clay		58	310	252
Blacksand & Blue Clay mix	X	310	400	90

N 41.022360
W 115.402799 NAD27

Date started: July 18, , 20 08
Date completed: 21-Jul , 20 08

9. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	400	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+3	400

Perforations:
Type of perforation Mill Slot
Size of perforation 3/16 x 3
From 360 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 60 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 60 to 400 ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: feet below land surface
Artesian Flow: 85 G.P.M. 20 P.S.I.
Water Temperature: cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Terry Minnerup / Fertig Drilling Company
Contractor
Address P.O. Box 525
Contractor
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 031904
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1584 T
Signed
By driller performing actual drilling on site or contractor
Date 2-3-09

(Rev. 05-09)

USE ADDITIONAL SHEETS IF NECESSARY