Corrected

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108057
Permit No.
Basin Ø44

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62606

1. OWNER Bridgette Drake
MAILING ADDRESS 293 Ryndon #5
Elko, Nv 89801

ADDRESS AT WELL LOCATION 6255 Taylor Ave - Ryndon
Elko, NV
Subdivision Name: HRR #1 County: Elko

2. LOCATION SW ¼ se ¼ Sec 31 T 36N N/S R 57 E
PERMIT/WAIVER No. 012-004-007
Issued by Water Resources Parcel No.

Latitude 40.57.28N
Longitude 115.35.27W
UTM E N NAD 83
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Luval		0	10	10
Sandy Gravel		10	30	20
Caliche		30	35	5
Gravel		35	40	5
Clay		40	48	8
Gravel	X	48	60	12
Clay		60	68	8
Clay/Gravel		68	180	112
Gravely Sand	X	180	200	20

N40.957857
W 115.589935 NAD27

Date started: 12-Aug, 20 08
Date completed: 14-Aug, 20 08

7. Water Level
Static water level: 62 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 60 °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	25		4

STATE ENGINEER'S OFFICE
2009 JAN 26 PM 2:25

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	188	+2	20
6 5/8		SDR-22	20	200

Perforations:
Type of perforation SDR-17 Screen
Size of perforation 0.032
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 200 ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fertig Drilling Company (Contractor)
Address P.O. Box 525 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 031904
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2367
Signed (By driller performing actual drilling on site or contractor)
Date 9-18-08

(Rev. 05-08) USE ADDITIONAL SHEETS IF NECESSARY