WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 108061
Permit No.
Basin Ø45

NOTICE OF INTENT NO. 60130

1. OWNER Robert & Michelle Carder
MAILING ADDRESS 168 Pleasant Valley Rd #4
89815

ADDRESS AT WELL LOCATION Not Established
268 Lazy T Ln

2. LOCATION NE ¼ NW ¼ Sec. 26 T. 33 N/S R. 57 E. Elko County
PERMIT NO. N/A (Issued by Water Resources) 023-011-002 (Parcel No.) Pleasant Valley Estates Lot 2 Blkk (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loamy Soil		0	1	1
Clay, sand, gravel, boulder		1	111	110
Coarse gravel	3gpm	111	112	1
Clay		112	120	8
Gravel	5gpm	120	123	3
Sandy clay		123	156	33
Sandy clay	total 9gpm	156	161	5
Clay, Sand, gravel	✓✓✓	161	181	20
T.D. 181				
~~N 40.71885 N~~				
~~W 115.51852 W NAD27~~				
G.P.S. 40.71885 N				
115.51852 W NAD27				
Elev. 5847				

Date started May 17/07, ~~19~~
Date completed May 31/07, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	20	1

8. WELL CONSTRUCTION
Depth Drilled 182 Feet Depth Cased 182 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10+ Inches	0 Feet	50 Feet
8 Inches	50 Feet	140 Feet
6 Inches	140 Feet	181 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	181

Perforations:
Type perforation Torch cut
Size perforation 1/8 x 4
From feet to feet
From 164 feet to 175 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to T.D. ± 181 feet

9. WATER LEVEL
Static water level [illegible] feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Muth Drilling Co. (Contractor)
Address 203 Pine St., Elko, NV 89801 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
Signed James V. Muth (By driller performing actual drilling on site or contractor)
Date 5-30-07

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627