WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 108062
Permit No.
Basin Ø45

NOTICE OF INTENT NO. 60131

1. OWNER Robert & Michelle Cardon
MAILING ADDRESS 166 Pleasant Valley Rd #4
89815

ADDRESS AT WELL LOCATION Not established
267 Crow Bar Ln

2. LOCATION SE ¼ NW ¼ Sec. 26 T. 33 N/S R. 57 E. Elko County
PERMIT NO. N/A (Issued by Water Resources) 023-011-009 (Parcel No.) Pleasant Valley Estates Lot 9 Blk K (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loamy Clay		0	3	
Cemented clay & gravel		3	30	
Streaks of sandy clay & gravel		30	37	
Coarse gravel & clay		37	51	
Vossil streambed Cobbles, gravel, sand		51	59	
Clay sand gravel	Seep	59	110	
Sand & clay	✓✓	110	160	
Sand & gravel	✓✓✓	160	176	
~~[illegible]~~				
~~W-115,[illegible]~~				
GPS 40.71875 N	NA27			
~~[illegible]~~ 57853 W	~~[illegible]~~			
Elev 5853				

Date started 6-15-07, 19
Date completed 7-2-07, 19

7. WELL TEST DATA

TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
17	10	2 hrs

8. WELL CONSTRUCTION
Depth Drilled 176 Feet Depth Cased 176 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10¾ Inches	0 Feet	51 Feet
8" Inches	51 Feet	111 Feet
6" Inches	111 Feet	176 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	12.92	.188	+1	176

Perforations:
Type perforation torch cut
Size perforation ⅛ x 4
From feet to feet
From 140 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 175 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature Cold °F Quality Excellent

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MUTH DRILLING Co. (Contractor)
Address 203 Pine St. Elko, NV 89801 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 10819
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632

Signed James V. Muth
By driller performing actual drilling on site or contractor
Date 7-3-07

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627