WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 108065
Permit No.
Basin 7-099

NOTICE OF INTENT NO. 52999

1. OWNER Albert Pond
MAILING ADDRESS 16255 Fetlock Dr. Reno NV. 89506
ADDRESS AT WELL LOCATION 16255 Fetlock Dr Reno NV 89506 N39.893934 W119.956697 NAD27

2. LOCATION SW ¼ SW ¼ Sec. 3 T. 23 N/S R. 18 E. Washoe County
PERMIT NO. Issued by Water Resources | 078/231/12 Parcel No. | Rancho Haven Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Rock & Clay		0	45	45
Br Clay		45	180	135
Bl Clay		180	210	30
Rock		210	224	14
Clay		224	230	6
Rock		230	238	8
Clay & Rock		238	277	39
Rock		277	291	14
Clay		291	306	15
Rock		306	313	7
Rock & Clay		313	335	22
Rock		335	339	4
Clay & Rock		339	382	43
Rock		382	388	6
Clay & Rock		388	404	16
Rock		404	420	16
Clay		420	430	10
Rock		430	440	10
Clay		440	505	65
Rock	X	505	560	55
N 39.88284	NAD 83			
W 119.95773				

Date started 8/15, 2007
Date completed 9/14, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	400	4

RECEIVED 2007 SEP 18 AM 10:26 STATE ENGINEER

8. WELL CONSTRUCTION
Depth Drilled 560 Feet Depth Cased 560 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	440 Feet
6 1/8 Inches		440 Feet	560 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	3/16	0	440
5	11	3/16	420	560

Perforations:
Type perforation Saw slot
Size perforation 3/16
From 200 feet to 240 feet
From 300 feet to 340 feet
From 380 feet to 440 feet
From 520 feet to 560 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 440 feet

9. WATER LEVEL
Static water level 28 feet below land surface
Artesian flow NO G.P.M. NA P.S.I.
Water temperature 58 °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Olenski Drilling & pump Co. (Contractor)
Address 15045 Red Rock Rd. (Contractor)
Reno NV 89508
Nevada contractor's license number issued by the State Contractor's Board 50343
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
Signed John F Olenski (By driller performing actual drilling on site or contractor)
Date 9/16/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627