

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108069
Permit No. 212
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34559

1. OWNER Owens Associates LLC ADDRESS AT WELL LOCATION 1600 N. Las Vegas Blvd.
MAILING ADDRESS PO Box 49272 Las Vegas, NV 89030
Los Angeles, CA 90049-0272 Subdivision Name: _____ County: Clark

2. LOCATION SW 1/4 SW 1/4 Sec 23 T 26 N R 61 E Latitude 36.188826° UTM E NAD 27
PERMIT/WAIVER No. 139-23-402-005 Longitude -115.133617 N NAD 83/WGS 84
Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test Cable Rotary RVC
 Municipal/Industrial Monitor Stock Air Other Auger

6. LITHOLOGIC LOG # 2

Material	Water Strata	From	To	Thick-ness
<u>Asphalt</u>		<u>0'</u>	<u>6"</u>	<u>.5</u>
<u>Type II</u>		<u>6'</u>	<u>2'</u>	<u>1.5</u>
<u>silty clay</u>		<u>2'</u>	<u>6'</u>	<u>4</u>
<u>caliche</u>		<u>6'</u>	<u>8'</u>	<u>2</u>
<u>clay w/some sand</u>	<u>17'</u>	<u>8'</u>	<u>25'</u>	

9. WELL CONSTRUCTION

Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
<u>8</u> inches	<u>0</u> inches	<u>25</u>	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>25</u>

Perforations

Type of perforation Factory slot

Size of perforation 0.20

From	feet to	feet	feet
<u>10</u>	<u>25</u>		

Annular Seal: Yes No

<input type="checkbox"/> Neat Cement	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	<u>0</u> to <u>6'</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> ≥30% Bentonite Grout	to _____	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack: Yes No 8' to 25' Pumped Poured

Type: #3 sand

Bentonite Chips: Yes No 6' to 8' Pumped Poured

Type: hole plug

Date started: April 10 2008
Date completed: April 10 2008

7. Water Level

Static water level: _____ feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ °F
Quality: _____

8. TEST METHOD: Bailor Draw Down

Time (Hours) _____
G.P.M. _____
(Feet Per Minute)

DENR/DWR RECEIVED
APR 17 2008
LAS VEGAS OFFICE

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Elite Drilling Inc. Contractor
Address 4255 W. Post rd. Contractor
Las Vegas, NV 89118
Nevada contractor's license number _____
issued by the State Contractor's Board 0054931
Nevada driller's license number issued by the _____
Division of Water Resources, the on-site driller M-1869

Signed [Signature]
By driller performing actual drilling on-site or contractor

Date 4/16/08

(Rev. 04-06)

USE ADDITIONAL SHEETS IF NECESSARY