STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108072
Permit No.
Basin 045

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59464

1. OWNER Ethan Scott
MAILING ADDRESS P.O Box 1839
Elko, NV 89803

ADDRESS AT WELL LOCATION 249 Lazy T Lane
Subdivision Name: County: Elko

2. LOCATION NE ¼ NW ¼ Sec 26 T 33N N/S R 57 E
PERMIT/WAIVER No. 023-010-008
Issued by Water Resources Parcel No.

Latitude 40.43.181N
Longitude 115.31.265W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam		0	3	3
Decomposed Granite		3	38	35
Clay		38	42	4
Cobble Boulder		42	43	1
Clay		43	59	16
Cobble Boulder		59	95	36
Sand & Gravel		95	97	2
Cemented Gravel		97	124	27
Clay		124	151	27
Cemented Gravel		151	158	7
Sand & Gravel	X	158	161	3
Cemented Gravel		161	172	11
Sand & Gravel	X	172	173	1
Clay		173	189	16
Cemented Gravel		189	196	7
Clay		196	224	28
Sand & Gravel	X	224	240	16
N 40.719774				
W 115.520182 NAD27				

Date started: 20, June, 20 07
Date completed: 25, June, 20 07

9. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
105/8	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	20
6		SDR-17	20	240

Perforations:
Type of perforation Screen
Size of perforation 0.032
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 20 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 55 to 240 ☐ Pumped ☒ Poured
Type: 3/8 PEA GRAVE;
Bentonite Chips: ☒ Yes ☐ No 20 to 55 ☐ Pumped ☒ Poured
Type: 3/8 Kiwk Plug

7. Water Level
Static water level: 102 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	65		25

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. dba FERTIG DRILLING COMPANY
Contractor
Address P.O. BOX 525
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 031904
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1584
Signed
By driller performing actual drilling on site or contractor
Date 7-19-07

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY