STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 108074
Permit No.
Basin 045

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60384

1. OWNER David Bouge
MAILING ADDRESS 169 Rocking Chair #9
Spring Creek, NV 89815

ADDRESS AT WELL LOCATION 348 Lazy T Lane
Subdivision Name: 40.43.138.N County: Elko

2. LOCATION NW ¼ NE ¼ Sec 26 T 33N N/S R 57 E
PERMIT/WAIVER No. 023-018-002
Issued by Water Resources Parcel No.

Latitude ~~40.43.138.N~~
Longitude ~~115.30.934W~~
115.30.934W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84
NAD83

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cobble Boulder		0	25	25
Clay		25	48	23
Cobble Boulder		48	59	11
Clay		59	88	29
Cobble Boulder		88	106	18
Clay		106	138	32
Cobble Boulder	X	138	141	3
Clay		141	182	41
Gravel & Sand	X	182	200	18

N 40.719040
W 115.514673 NAD27

Date Started 25-Jun, 20 07
Date Completed 1-Jul, 20 07

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
105/8	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	20
6		SDR-17	20	200

Perforations:
Type of perforation Screen
Size of perforation 0.032
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 20 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 51 to 200 ☐ Pumped ☐ Poured
Type: 3/8 PEA GRAVE;
Bentonite Chips: ☒ Yes ☐ No 20 to 51 ☐ Pumped ☒ Poured
Type: 3/8 Kiwk Plug

7. Water Level
Static Water Level 136 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	50		16

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. dba FERTIG DRILLING COMPANY
Contractor
Address P.O. BOX 525
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the 031904
Nevada driller's license number issued by the Division of Water Resources, the 1584
By driller performing actual drilling on site or contractor
7-19-07

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY