WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 108081
Permit No.
Basin Ø87

NOTICE OF INTENT NO. 34545

1. OWNER Olympia Gaming LLC
MAILING ADDRESS 11411 Southern Highland Prwy
Las vegas, NV, 89141

ADDRESS AT WELL LOCATION Spark marina
E. side of lake at the Legens site.
N39.533055 W119.721093 NAD27

2. LOCATION NW ¼ NE ¼ Sec. 10 T. 19 N/S R. 20 E. Washoe County

PERMIT NO. M/D-1474 (Issued by Water Resources) 037-030-46 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other Temp

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG #2

Material	Water Strata	From	To	Thickness
Fill		0	4'	
Gravel w/clay		4	5'	
Gravel w/sand		5	10	
clay		10	16	
Gravel		16	17	
Clay	17'	17	22	
Gravel		22	40	

39°31'58.60834"N
119°43'19.54776"W

~~Lat 39.5312~~ ~~WGS 84~~
~~Long 119.7252~~

Date started 12-6, 2007
Date complated 12-6, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

2007 DEC 13 AM 11:37

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	PVC	Sch 40	0	40

Perforations:
Type perforation Factory slot
Size perforation .020
From 10 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 8' to surface
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 8 feet to 40 feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc. (Contractor)
Address 4255 W. Post rd (Contractor)
Las vegas, NV 89118
Nevada contractor's license number issued by the State Contractor's Board 0054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed [signature] By driller performing actual drilling on site or contractor
Date 12-10-07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627