


STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY *108092*

Log No. _____
Permit No. _____
Basin 134

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61064

1. OWNER General Moly
MAILING ADDRESS 2215 N. 5th Street
Elko, NV 89801

ADDRESS AT WELL LOCATION Mt. Hope
Hole #TFX-2
Subdivision Name: _____ County: Eureka

2. LOCATION NW 1/4 SW 1/4 Sec 5 T 21HN N/S R 52 E
PERMIT/WAIVER No. W-634B
Issued by Water Resources / 77553 Parcel No. _____

Latitude _____ UTM E 573133 NAD 27
Longitude _____ N 4396146 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silty Sand		0	20	20
Clay Stone		20	80	60
Mud Stone		80	1000	920
Cement		0	12	12
10 - 94# Bags				
3/8" Bentonite Chips		12	35	23
11 - 50# Bags				
Super Plug		35	229	194
16 - 50# Bags				
#60 Sand		229	250	21
19 - 50# Bags				
1/4" Gravel		250	1000	750
9 - Super sacks				

N39.712122
W 116.145919 NAD27

9. WELL CONSTRUCTION

Depth Drilled	1000	Feet	Depth Cased	1000	Feet
HOLE DIAMETER (BIT SIZE)					
	From		To		
18	Inches	0	Feet	19.5	Feet
12.25	Inches	19.5	Feet	1000	Feet
	Inches		Feet		Feet
CASING SCHEDULE					
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)	
14		.25	+5	19.5	
8		.188	+2	1000	
Perforations:					
Type of perforation	Vertical Mill Slot Louvered				
Size of perforation	1/8"				
From	+2	Blank	feet to	300	feet
From	300	Louvered Screen	feet to	520	feet
From	520	Blank	feet to	620	feet
From	620	Mill Slot Screen	feet to	980	feet
From	980	Blank	feet to	1000	feet
Annular Seal: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
<input checked="" type="checkbox"/> Neat Cement	0	to 12	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured	
<input type="checkbox"/> Cement Grout			<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
<input type="checkbox"/> Concrete Grout			<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
<input checked="" type="checkbox"/> ≥30% Bentonite Grout	35	to 229	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured	
Gravel Pack:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	229	to 1000	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
Type:	1/4" Gravel 250' - 1000' / #60 Sand 229' - 250'				
Bentonite Chips:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12	to 35	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
Type:	3/8" Chips				

Date started: 20-Nov 20 08
Date completed: 9-Dec 20 08

7. Water Level
Static water level: 240 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: Cool °F
Quality: Clear

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
at TD	100		

STATE ENGINEER'S OFFICE
SI-8 11 02 MAR 2008

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc. Contractor
Address PO Box 2748 Contractor
Elko, NV 89803
Nevada contractor's license number _____
issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the _____
Division of Water Resources, the on-site driller 2330
Signed Jason Poole by (signature)
By driller performing actual drilling on site or contractor
Date 1/15/2009

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY